WHITE MARSH
ENVIRONMENTAL SYSTEMS, INC.
1100 South Little Creek Road
Dover, Delaware 19901

WATER USEAGE FOR THE TOWN OF FRANKFORT
AUG. 2012

	Beginning Reading	Ending Reading	Totaled Pumped
Well # 2	3400000	5647300	2,247,300
Well # 4			
Totaled Pumped from both Wells			2,247,300

Total Backwashes		SYSTEM Beginning	SYSTEM Ending	Totaled Pump
		52702000	54973000	2,271,000
Caustic used	645gal	Avg. Gal. Per Day		73,258
CL2 used	264gal	Water used to backwash		
Polymer used	884lb	Water decanted back		27,940
Fluoride used	0gal			

302-734-7500 1-800-523-7224 fax 302-734-9295