

Dover, Delaware 19901

WATER USEAGE FOR THE TOWN OF FRANKFORD

MARCH. 2012

Well # 2	Beginning Reading 91071200	Ending Reading 93433500	Totaled Pumped 2,362,300
Well # 4			0
Totaled Pur	mped from both Wells		2,362,300
Total Back	washes 0		
Caustic use	d 672gal		
CL2 used	255gal		
Polymer us	ed 9441b		
Fluoride us	ed 0gal		